

MINNESOTA STATE DEPARTMENT OF PUBLIC SAFETY



Alcohol &
Gambling
Enforcement

Bureau of
Criminal
Apprehension

Capitol Security

Crime Victim
Services

Driver & Vehicle
Services

Emergency
Management /
Emergency
Response
Commission

State Fire
Marshal /
Pipeline Safety

State Patrol

Traffic Safety



State Fire Marshal Division

444 Cedar Street, Suite 145, St. Paul, Minnesota 55101-5145

Phone: 651/201-7200 FAX: 651/215-0525 TTY: 651/282/6555

Internet: <http://www.fire.state.mn.us>

SPECIAL EXITING PROVISIONS IN EDUCATIONAL OCCUPANCIES- ROOMS USED BY CERTAIN AGE STUDENTS ABOVE OR BELOW THE LEVEL OF EXIT DISCHARGE

MSFC (07) Section 1001.3 (as amended by Minnesota Rules, part 7510.3580, subpart 1) requires that rooms in Group E Occupancies used by preschool, kindergarten, first- or second-grade students be located as required by the Building Code.

MSBC Section 421 – as amended by Minnesota Rules, part 1305.0419:

419.2.1 School buildings equipped with complete automatic fire sprinkler and fire alarm systems. Rooms used by preschool, kindergarten, and first and second grade students for classrooms, latchkey, day care, early childhood family education, teen parent, or similar programs may be located on any floor level below the fourth story if the following conditions exist:

1. The building is protected throughout with an approved automatic fire sprinkler system; and
2. The building is protected throughout with an approved automatic fire alarm system having automatic smoke detection devices installed throughout the exit system within every room or area used for purposes other than a classroom or office.

419.2.2 School buildings equipped with either a complete automatic fire sprinkler system or a fire alarm system. Rooms shall be located on the story of exit discharge when used for the purposes of classroom, latchkey, daycare, early childhood education, teen parent, or similar programs by preschool, kindergarten, or first grade students. Rooms shall be located on the story of exit discharge or one story above when used for any purpose by second grade students.

Rooms occupied by preschool, kindergarten, first, or second grade students, when used for the programs described in this section, may be located on floor levels other than those designated above if one of the following conditions is met:

1. An approved automatic fire sprinkler system is provided throughout the building and the use of the affected room or space is limited to one grade level at a time and exiting is provided from the room or space which is independent from the exiting system used by older students; or
2. A complete approved automatic fire alarm system is installed throughout the building consisting of automatic smoke detection installed throughout the exit system and within all rooms and areas other than classroom and office areas, and the use of the affected room or space is limited to one grade level at a time, and exiting is provided from the room or space which is independent from the exiting system used by older students.

For the purposes of this subpart, pupils from the second grade down are considered one grade level.

- auto sprinklers or auto fire alarm ok ok ok ok ok ok ok ok

ok = permitted / np = not permitted / LED = level of exit discharge