



**MINNESOTA DEPARTMENT OF PUBLIC SAFETY
State Fire Marshal Division**

STATEMENT of POLICY

Policy #: FP-08 (2007)	Subject of Interpretation: Wet Kitchen Hood Systems in the Remote Area	
Approved By: Jerry Rosendahl	Title: State Fire Marshal	Effective Date: July 10, 2007

APPLIES TO:

Fire Safety Supervisors and Inspectors, Fire Protection System Supervisors, Inspectors and Plan Reviewers, Fire Protection System Contractors, Designers and Installers.

PURPOSE:

To clarify the fire sprinkler design parameters when a wet kitchen hood system falls within a hydraulically remote design area.

When kitchen hoods are located in a hydraulically remote area of a sprinkled building, the remote area must be expanded to include the required size (typically 1,500 sq. ft.) plus the additional flow and pressure required by the hood's extinguishing system. [See Fire Marshal Code Advisory Panel File #95-029-1]