



# INSPECTION CHECKLIST

## Common Fire & Life Safety Deficiencies

Y = Meets Requirements; N= Does Not Meet Requirements

Y N

### EXTERIOR:

- Fire Lanes marked/unobstructed (MSFC 503.3, 503.4)
- Address visible (MSFC 505.1)
- Fire hydrants/water supply accessible (MSFC 508)
- Combustible accumulations/storage acceptable (MSFC 304.2, MSFC 315.3)
- F.D. key box present/maintained (MSFC 506)
- F.D. connections visible/maintained (MSFC 912)
- Gas meter/piping protected against impact (MSFC 312, 603.9)

### EXIT FEATURES/MEANS OF EGRESS:

- Adequate number of exits (MSFC 1004.4, 1015, 1019, 1027.23)
- Exits, aisles, & corridors free of obstructions (MSFC 1028.3)
- Exit doors open from inside (MSFC 1008.1.8)
- Exit signs present (MSFC 1011, 1027.3)
- Emergency lighting present & operational (MSFC 1006, 1027.5)
- Interior finish acceptable (MSFC 803, 804)
- Exit corridors rated (MSFC 1017.1, 1027.17.1)

### CONSTRUCTION FEATURES:

- Fire rated construction present/maintained (MSFC 703.1)
- Incidental use areas separated/sprinklered (MSFC 705.3)
- Rated fire doors operational (MSFC 703.2)
- Vertical openings protected (MSFC 704.2)

### STORAGE:

- Storage neat and orderly (MSFC 315.2)
- Combustible storage prohibited in electrical equipment rooms, restrictions apply in boiler/mechanical rooms (MSFC 315.2.3)
- Attic storage (MSFC 315.2.4)
- Storage maintained [2' below ceiling un-sprinklered, 18" sprinklered] (MSFC 315.2.1)
- Rubbish/waste subject to spontaneous ignition shall be disposed of daily and in listed container (MSFC 304.3.1)
- Decorations (foams, curtains, drapes, hangings) to be flame resistant in assembly occupancies (MSFC 807.1, 807.4.2)

### FLAMMABLE/COMBUSTIBLE LIQUIDS:

- Safety containers if used (MSFC 3405.2.4)
- Not stored/kept near exits (MSFC 3404.3.3.3)
- No sources of ignition (MSFC 3404.2.4)
- Quantities >10 gals in cabinet (MSFC 3404.3.4.4)
- Adequate ventilation (MSFC 3405.3.7.5.1)

Y N

### UTILITY/MECHANICAL/HVAC:

- Shut off valves present on gas appliances (MSFC 603.1)
- Approved piping, connections & appliances used (MSFC 603.1.2)
- Combustion air supply/venting present (MSFC 603.1)
- Adequate clearance between combustibles and appliances (MSFC 305.1, 603.5.3)
- Commercial hood ducts/filters are clean (MSFC 904.11.6.3)

### SPRINKLER SYSTEM:

- Coverage is adequate (MSFC 903.3.1)
- Controls are readily accessible (MSFC 903.3.1)
- Valves locked open (MSFC 903.4.4)
- System and valves supervised [>20 sprinklers new, ≥ 100 in existing] (MSFC 903.4)
- Heads in good condition (MSFC 903.3.1)
- Wrench/spare sprinklers present (MSFC 903.3.1)
- Tested/inspected at least annually (MSFC 901.6.1)
- Riser/pump rooms labeled (MSFC 510.1)

### FIRE ALARM & DETECTION SYSTEMS:

- Control panel/annunciator panel in normal condition [no trouble or alarm conditions] (MSFC 901.6, 901.7)
- Detectors properly installed (MSFC 907)
- Tested/inspected at least annually (MSFC 907.20)

### OTHER FIRE PROTECTION SYSTEMS:

- Standpipes needed (MSFC 905)
- Standpipes/hose in good condition (MSFC 905.2)
- Adequate coverage (MSFC 905.2)
- Hood system fuel shutoff present (MSFC 904.11.2)
- Hood system properly maintained/serviced (MSFC 904.11.6)

### ELECTRICAL:

- No electrical hazards (MSFC 605.1, 605.6)
- Appliances/fixtures in good condition (MSFC 605.7)
- Overcurrent protection present (MSFC 605.1)
- Multi-plug adapters not used (MSFC 605.4)
- Extension cords not substituted for fixed wiring (MSFC 605.5)
- Power strips properly used (MSFC 605.4)
- Access/clearance to electrical panels (MSFC 605.3)

### HAZARDOUS MATERIALS:

- Compressed gas cylinders secured (MSFC 3003.5)
- Rooms/areas properly labeled (MSFC 2703.5)
- Acceptable quantities (MSFC 2703.1.1)
- Separation of incompatible materials (MSFC 2703.9.8)

Version 1.0 effective 9/12/11

This checklist is intended as a guide to assist fire inspection personnel in identifying general fire and life safety hazards, other possible code requirements may apply. Please refer to other checklists for information on certain occupancies/topics.

MSFC = Minnesota State Fire Code