

Annual Fire Extinguisher Maintenance Report

Name of Property: _____ Date: _____

Inspected by: _____ Signature: _____ Affiliation: _____
[Print]

According to NFPA 10-2010, section 7.3.1.1, fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. Every 6 years, stored pressure fire extinguishers that require a 12-year hydrostatic test shall be emptied and subjected to the applicable internal examination procedures as detailed in the manufacturer’s service manual.

Brand	Serial Number	Asset Number	Location	Type	Capacity (Lbs.)	"Pass" or "Fail" Annual Maintenance	Last 6-Year/Hydro Service		Next 6-Year/Hydro Service	
							Date	Type of Service	Date	Type of Service